


How Monitor Alarm Set Points Affect Real World Operator Level Behaviors



*Bob Comer, District Manager
Industrial Scientific Corporation
Cell 916-203-5847
Email Bcomer@indsci.com*

Real World Behaviors



Real World Behaviors



Real World Behaviors



Real World Behaviors



Operational Problems with Direct Reading Monitors

- Monitors are typically used because they detect things we cannot *reliably* detect by ourselves



Operational Problems with Direct Reading Monitors

- Cross interferences can cause a false positive on a monitor—leading to confusion about what’s “*really there.*”
- Not infrequently when monitors go into alarm the operator assumes there is something wrong with the *monitor*—“because we never have *that* problem”
- Some gas concentrations directly affect judgment
- Two or more monitors can give different readings. Operators will ~~almost~~ *always* believe the one that reads “clean”.

Operational Problems with Direct Reading Monitors


- Causes of different readings:
 - The “clean” reading monitor may be defective
 - More typically differences are associated with one monitor drawing a remote sample and the other monitor being in diffusion. Differences can be caused by
 - Incorrect sample tubing
 - Incorrect wait to sample draw times
 - Another cause of different readings is a monitor being improperly zeroed in “Bad Air” either a contaminated environment or a residual chemical poisoning.

Operational Problems with Direct Reading Monitors

- Operators may also assume a monitor is giving a false positive when the monitor goes into alarm in a confined space but then *stays* in alarm in fresh air.
- The monitor may “*legitimately*” continue in alarm in fresh air for a number of reasons:
 - Chemical poisoning
 - Age of the sensor


Operational Problems –Chemical Poisoning

- Typical curve of a monitor poisoned by exposure to an unsaturated hydrocarbon such as a monitor that was cleaned with a solvent or exposed to an air freshener spray.





Operational Problems –Chemical Poisoning

- The datalog curve of the same monitor the next day



- Typical curve of an actual CO exposure. Note the rapid recovery of the sensor. This exposure did result in a TWA alarm





Operational Problems –Chemical Poisoning

- So how much does the typical operator want to know about alarms due to chemical poisoning?



Operational Problems with Direct Reading Monitors

- Other factors leading to “False Alarms”
- The monitor may also be in alarm for other reasons not understood by the operator
 - TWA or STEL alarm (more typically TWA)
 - Latched LEL alarm
 - Over ranged LEL alarm
 - Sensor is in Failed condition
- Operators may prefer to think the monitor is bad rather than that they need more training.

Operational Problems with Direct Reading Monitors

- Or
me
Tir


Longest Duration



| Time: | Duration: | Gas: |
|---------------------|-------------|----------------|
| 9/12/2017 6:48 AM | 11h 19m 30s | Oxygen |
| 9/4/2017 7:02 PM | 11h 5m 10s | Oxygen |
| 10/23/2017 8:12 AM | 9h 35m 30s | Oxygen |
| 10/16/2017 7:09 AM | 9h 30s | Oxygen |
| 10/21/2017 11:02 AM | 7h 49m 40s | Sulfur Dioxide |
| 10/31/2017 6:38 AM | 4h 49m 40s | Oxygen |

Operational Problems with Direct Reading Monitors

This is the actual datalog of the O2 reading showing no O2 in the environment—remember that the monitor was continuously in alarm on 10/23 for over 9 hours



Operational Problems with Direct Reading Monitors

In terms of Operator error you might think this monitor was not bump tested

| Equipment Category | Time | Result | Reason | Activity | Duration |
|--|--------------------|--------|-----------|-----------|----------|
| Instrument | 11/11/2017 5:05 AM | Failed | Scheduled | Bump Test | 61 |
| Instrument | 11/4/2017 6:16 AM | Passed | Forced | Bump Test | 148 |
| Instrument | 11/4/2017 6:08 AM | Failed | Forced | Bump Test | 181 |
| Instrument | 11/4/2017 6:02 AM | Failed | Forced | Bump Test | 76 |
| Instrument | 11/4/2017 5:42 AM | Failed | Forced | Bump Test | 63 |
| Instrument | 10/18/2017 4:28 AM | Failed | Forced | Bump Test | 69 |
| Instrument | 10/8/2017 5:35 AM | Failed | Forced | Bump Test | 65 |
| Instrument | 10/7/2017 5:24 AM | Failed | Scheduled | Bump Test | 184 |
| Instrument | 9/20/2017 10:55 AM | Passed | Scheduled | Bump Test | 63 |
| Instrument | 9/20/2017 10:42 AM | Passed | Scheduled | Bump Test | 112 |
| Instrument | 9/19/2017 7:54 AM | Passed | Scheduled | Bump Test | 121 |
| Remember that the monitor was used on 10/23 | | | | | |
| Instrument | 9/9/2017 4:52 AM | Passed | Scheduled | Bump Test | 74 |


Operational Problems with Direct Reading Monitors

So in this first case we saw a monitor left in alarm due to a (defective) worn out sensor. Did the operator carry the monitor with him continuously in alarm—or did he leave it in his truck?

What can we do to keep operators safe when they are working in environments hazardous enough to require monitoring but not hazardous enough for them to care?

Operational Problems with Direct Reading Monitors

Monitors may also be driven into a TWA alarm if the Datalogs are not cleared and re-set.



Operational Problems with Direct Reading Monitors

In this case the monitor was actually in TWA alarm for 13 hours and 37 minutes but the monitor “read” 0.

Alarm

| | |
|-----------------------------|-------------------------------------|
| Sensor SN: | VIRTUAL#17032WV170#17032WV173#S0002 |
| Gas Code Description: | Hydrogen Sulfide |
| Factor: | |
| Type: | TWA |
| Start Time: | 8/14/2017 4:17:01 PM |
| End Time: | 8/15/2017 5:54:01 AM |
| Duration: | 13h 37m |
| Average Reading: | 0.5 ppm |
| Datalog Recording Interval: | 10s |
| Datalog Peak Reading: | 0.7 ppm |
| Instrument Peak Reading: | 0 ppm |
| Upload Time: | 8/15/2017 5:56:28 AM |

Operational Problems with Direct Reading Monitors


- So a number of errors can cause the operator to “lose confidence in the monitor.”
- Monitors are typically used because they detect things that cannot *reliably* be detected without them.
- Operators want them to just be like hard hats.
- What are some of the behaviors by the operators
 - Turning the monitor off while in alarm
 - Leaving the monitor on but in the truck
 - Push buttons on the monitor until it stops making noise (re-zeroing the monitor-inadvertently clear TWA)

Operational Problems with Direct Reading Monitors

- Another problem associated with Operator error is assuming the monitor is wrong so what it is reporting is not what is there at all—is must be something else
- *“We were in clean air the whole time—we couldn’t have any CO exposure so what caused these readings?”*
 - *(they were outside but they were standing between two gas generators powering welding equipment)*

Operational Problems with Direct Reading Monitors


- We're working in a confined space that was open at the top so what is causing these CO readings?



What sort of work?

Using Gas Powered Equipment as part of excavation—but we have a “fan” in the space—no it was not an exhaust fan—it was just a fan.


Reading (ppm)



— Reading — TWA — STEL — Instrument Alarm Event — Peak Reading

Operational Problems with Direct Reading Monitors

- This did result in a TWA reading but note that the TWA is below the alarm threshold



Alarm

Sensor SN: 16041K2040#S0001

Gas Code Description: Carbon Monoxide

Factor:

Type: High

Start Time: 11/10/2017 7:53:06 AM

End Time: 11/10/2017 8:31:16 AM

Duration: 38m 10s

Average Reading: 148.9 ppm

Datalog Recording Interval: 10s

Datalog Peak Reading: 244 ppm

Instrument Peak Reading: 0 ppm

Upload Time: 11/10/2017 1:19:38 PM

Concerns resulting from Operational Problems

- Operators may become desensitized to alarm conditions—*normalization of deviation*
 - They may believe that monitors are too sensitive and that the alarms are just nuisances
 - If they get alarms and no one does anything about them, they may assume the alarms are not really all that important
 - Ignoring one aspect of safeguards increases the level of comfort for disregarding other safeguards

Concerns resulting from Operational Problems

- Operators may follow procedures but not be able to get any work done
- Or following the procedures takes too long and is too expensive
 - Too time consuming
 - Monitor maintenance is too expensive
 - Requires additional training
 - Requires calibration gas and spare parts

Mitigating Operational Problems

- Some problems are found more frequently in different industries. Water treatment operating environments are not the same as refining, or mining; however similar operational problems occur everywhere.
- Remember the bases of the problem:

Operational Problems with Direct Reading Monitors

- Monitors are typically used because they detect things we cannot *reliably* detect by ourselves
- Cross interferences can cause a false positive on a monitor
- Not infrequently when monitors go into alarm the operator assumes there is something wrong with the *monitor*—because we never have *that* problem
- Some gas concentrations directly affect judgment
- When two or more monitors are giving different readings Operators will believe the one that reads “clean”.


Operational Problems with Direct Reading Monitors

- “I can’t detect it without the monitor so I have no way of knowing if its *really* a problem.”
- “Safety tells me that I have to have this but production is telling me to get my job done.”
- This monitor is in my way
 - Which is easier:
 - Getting rid of the gas hazard?
 - Getting rid of the monitor?

Mitigating Operational Problems


Solutions?

- Buy monitors that don't go into alarm (?)
 - Driven by Operator Selection
 - Driven by incorrect application of technology



IR sensors are inherently non-linear

Technology can be complicated



Mitigating Operational Problems

Solutions?

- Simpler automation (Bad Ideas)
 - Sensor Response Gain Escalators
 - No real time fault indicators
 - Turn off Calibration and Bump Test Reminders
 - Clearing TWA on Monitor Re-Start or clearing peak readings
 - Utilize Rolling TWA calculations rather than true Time Weighted Averages

Mitigating Operational Problems

Solutions?

- Better accountability for field level alarms
- Better, more solutions oriented training
- Utilize the TWA alarms
 - Most agencies simply set the low alarm set point to the TWA
 - ***If Cal OSHA passes the new TWA of 1 ppm H₂S then Operational Problems associated with how the monitor handles TWA this is going to become more important***

Mitigating Operational Problems

Solutions?

- Better accountability for field level alarms

People ▾ Equipment ▾ Administration ▾ Reports ▾ INet Now ▾ Help ▾ EQUIPMENT ▾ Search

Click here to group by that column

| Instrument SN | Gas Code Description ▾ | Alarm Time | Alarm Types | Duration (seconds) ↑ |
|---------------|------------------------|------------------------|-------------|----------------------|
| 16043BG-001 | Carbon Monoxide | 9/7/2017 9:23:11 AM | Low | 1 |
| 16043BG-001 | Carbon Monoxide | 9/7/2017 10:34:10 AM | Low | 1 |
| 16043BG-001 | Carbon Monoxide | 9/7/2017 10:34:13 AM | Low | 1 |
| 16043BG-001 | Carbon Monoxide | 9/7/2017 11:20:01 AM | Low | 1 |
| 15102H5-005 | Oxygen | 9/7/2017 2:10:55 PM | Low | 1 |
| 15090ZV-003 | Oxygen | 9/14/2017 12:16:34 PM | Low | 1 |
| 11111H9-001 | Combustible Gas | 9/15/2017 11:42:38 AM | | 1 |
| 131121W-001 | Oxygen | 9/20/2017 1:58:54 PM | Low | 1 |
| 1609340-021 | Carbon Monoxide | 10/17/2017 11:04:30 AM | Low | 1 |
| 13034QD-003 | Carbon Monoxide | 11/29/2017 8:17:29 AM | Low | 1 |
| 13034QD-003 | Carbon Monoxide | 11/29/2017 8:18:11 AM | Low | 1 |
| 13034QD-003 | Carbon Monoxide | 11/29/2017 8:20:24 AM | Low | 1 |

Mitigating Operational Problems

Solutions?

- Better accountability for field lever alarms

| Instrument SN | Gas Code Description ▼ | Alarm Time | Alarm Types | Duration (seconds) ↑ |
|---------------|------------------------|-----------------------|-------------|----------------------|
| | | | | 60 × |
| 140832Q-007 | Hydrogen Sulfide | 9/1/2017 8:23:21 AM | High | 60 |
| 170245R-002 | Oxygen | 9/5/2017 9:16:43 AM | Low | 60 |
| 16043BG-001 | Oxygen | 9/7/2017 7:26:21 AM | Low | 60 |
| 14030RN-001 | Hydrogen Sulfide | 9/7/2017 7:37:33 AM | High | 60 |
| 14030RN-001 | Oxygen | 9/7/2017 7:37:33 AM | Low | 60 |
| 14030RN-001 | Combustible Gas | 9/7/2017 7:37:33 AM | Critical | 60 |
| 16043BG-001 | Carbon Monoxide | 9/7/2017 11:20:06 AM | Low | 60 |
| 15092SZ-001 | Oxygen | 10/25/2017 1:49:18 PM | Low | 60 |
| 17102V2-001 | Combustible Gas | 11/27/2017 1:13:11 PM | High | 60 |
| 17102V2-001 | Combustible Gas | 11/27/2017 1:15:47 PM | High | 60 |
| 15081YM-001 | Combustible Gas | 11/27/2017 1:49:32 PM | Critical | 60 |
| 16043BG-001 | Oxygen | 9/7/2017 9:22:27 AM | Low | 70 |

Mitigating Operational Problems

Solutions?

- Better accountability for field lever alarms


Dashboard People Equipment Administration Reports INet Now Help EQUIPMENT Search

a column header here to group by that column

| View Graph | Instrument SN | Gas Code Description ▼ | Alarm Time | Alarm Types | Duration (seconds) ↑ |
|----------------------------|---------------|------------------------|-----------------------|----------------|----------------------|
| | | | | Critical × | 60 |
| View Graph | 14030RN-001 | Combustible Gas | 9/7/2017 7:37:33 AM | Critical | 60 |
| View Graph | 15081YM-001 | Combustible Gas | 11/27/2017 1:49:32 PM | Critical | 60 |
| View Graph | 140701B-001 | Oxygen | 11/7/2017 7:50:19 PM | Critical | 80 |
| View Graph | 14030RN-001 | Combustible Gas | 9/19/2017 1:45:59 PM | Critical | 90 |
| View Graph | 1604277-001 | Oxygen | 11/1/2017 2:00:41 PM | Critical | 100 |
| View Graph | 17100YQ-001 | Combustible Gas | 11/29/2017 7:00:04 AM | Critical | 100 |
| View Graph | 17100YQ-001 | Combustible Gas | 11/29/2017 7:02:23 AM | Critical | 150 |
| View Graph | 161117M-034 | Oxygen | 11/1/2017 1:50:56 PM | Critical | 170 |
| View Graph | 13034QD-003 | Carbon Monoxide | 11/28/2017 1:02:02 PM | Critical, TWA | 310 |
| View Graph | 13034QD-003 | Carbon Monoxide | 11/28/2017 9:27:42 AM | Critical, STEL | 440 |
| View Graph | 13034QD-003 | Carbon Monoxide | 11/28/2017 9:19:02 AM | Critical, STEL | 520 |
| View Graph | 131121W-001 | Oxygen | 9/6/2017 7:37:26 AM | Critical | 19660 |

Operational Problems with Direct Reading Monitors

- This does result in a TWA but note that the TWA is below the alarm threshold



Mitigating Operational Problems

Solutions

- Set appropriate Instantaneous and TWA alarms
- Review Utilization and Alarm Data
- Reduce the number of Exposure Alarms
 - Start with the longest duration and greatest risk
- Reduce the number of *false* positives
 - Have the correct monitor for the correct application (H2 Null sensors in H2 areas)
 - Have targeted rather than general training
 - Involve your Gas Monitor Representatives early and often